

GUARDIAN FIRE TESTING LABORATORIES, INC.

480 Hinman Ave.
Buffalo, NY 14216

Product Certification

Accredited By American National Standards Institute (ANSI) To: ISO 17065

Roseburg MDF Medford

2685 North Pacific Hwy.
Medford, OR 97504


“Medite FR MDF” (542) Nominal 1/2” through 1-1/2” Thick; Standard: ASTM E84, Rating Class “A”;
Test Report, GL 60114, 8/30/14

“Medite FR MDF” (635) Nominal 1/4” up to 1/2” Thick; Standard: ASTM E84, Rating Class “A”;
Test Report GL 67515, 8/22/15

“Medite FR MDF” ((542) Nominal 1/2" through 1-1/2" Thick; Standard: CAN/ULC S102, Flame Spread
Rating (FSR) of 15; Smoke Developed Classification (SDC) of 5; Test Report GL 49215, 7/3/2015

“Medite FR MDF” (542) Nominal 3/8” through 1-1/2” Thick; Standard: ASTM E2768 (extended time),
Rating Class “A”; Test Report GL-6-2-17Z, 7/11/17

“Arreis” (437) MDF, Nominal 1/4" up to 1/2", ASTM E84, Rating Class C, GL ASTM E84, 7/6/17



Administrative Division Manager

Certifying Product Reliability Against Fire

RE-ISSUE DATE: January 3, 2018